

## **ADDENDUM “A”**

### **Request for Bids RFB #14-0603**

#### **CONSTRUCTION of UWHARRIE AMBULANCE BASE**

THIS ADDENDUM HEREBY CLARIFIES, MODIFIES, or RESPONDS to QUESTIONS received regarding the Randolph County **Request for Bids #14-0603** for the CONSTRUCTION of the UWHARRIE AMBULANCE BASE issued on Wednesday, June 4, 2014. This Addendum is being issued to notify potential Contractors of changes, additions, or needed clarifications that are being made to the specifications of **RFB #14-0603**.

The following are the question(s) that have been received by Randolph County and the County's response:

***Question 1.*** *Will a performance and payment bond be required for this project? What about a bid bond?*

**Answer:** No. Neither a bid bond or a performance and payment bond are required with this RFB or on the Construction of the Uwharrie Ambulance Base.

***Addition 1.*** *Randolph County Wastewater Construction Permit #2014-00000058 can be found on pages 2 thru 4 of **Addendum “A”**.*

Issued Thursday, June 12, 2014



COUNTY OF RANDOLPH  
Health Department  
204 E Academy St - Asheboro NC 27204-0771

**AUTHORIZATION FOR WASTEWATER  
SYSTEM CONSTRUCTION PERMIT**

Authorizations for Wastewater System Construction are valid for 5 years from the date of issuance, not to exceed the validity of the Improvements Permit, and are required before other construction permits can be issued. After expiration, a preconstruction conference with the owner or developer, or an agent of the owner or developer, and the Health Department shall be required. Upon satisfactorily showing to the Health Department that the site and soil conditions are unaltered, the proposed facility, site plan or plat has not changed, design wastewater flow and wastewater characteristics have not increased, and that the wastewater system can be installed according to the regulations that were in effect on the date the Improvements Permit was issued, a revised Authorization for Wastewater System Construction, that includes current technology that can reasonably be expected to improve the performance of the system, will be issued.

Permit Type: SEPTIC NEW

Applicant Name: ARTHURS, PAXTON  
Address: 725 MCDOWELL RD.  
City, St. Zip: ASHEBORO, NC 27205  
Phone: 336 318-6605

Permit #: 2014-00000058  
Parcel #: 7625275672

Contact: WELLS, RICHARD  
Contact Phone: 336 318-6302

Owner: SHAW FARMS LLC  
Address: 6372 HIGH PINE CHURCH RD  
City, St. Zip: ASHEBORO, NC 27205

**LOCATION INFORMATION:**

Address: 6372 HIGH PINE CHURCH RD ASHEBORO, NC 27205

Township: 20 - UNION  
Acreage: 87.45

Subdivision Name:  
Lot Number:

**FACILITY INFORMATION:**

Proposed Use: SINGLE FAMILY RESIDENCE  
Design Flow: 240  
Number Of Bedrooms: 2  
Number Of People/Employees: 4  
Number Of Shifts:

Basement: NO  
Basement Fixtures:

Dispersal Type: GRAVITY  
Wastewater System Type: GRAVEL TRENCH

Drainfield Size: 290 LINEAR FEET  
Septic Tank Size: 1000 GALLONS

Trench Depth: 24 INCHES  
Trench Width: 36 INCHES  
Stone Depth: 12 INCHES  
Cover Depth: 12 INCHES

Conditions: INSTALL ON CONTOUR, ESTABLISH GRASS COVER AFTER INSTALLATION, DO NOT DRIVE OVER ANY PORTION OF SYSTEM

Number of Conditional Attachments: 1

**DO NOT GRADE OR DISTURB THE APPROVED SEPTIC AREA!** This permit is subject to revocation if the site and soil conditions are altered, the proposed facility, site plan or plat has changed, and the design wastewater flow or wastewater characteristics have increased. The wastewater system shall be inspected and approved by the Health Department prior to covering and placing the system into use. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Issued By: WAYNE JONES  
Date Issued: 04/25/2014  
Expiration Date: 04/25/2019

Environmental Health Specialist

- LOCAL TELEPHONE NUMBER -  
Asheboro: (336) 318-6262 - Greensboro/Liberty: (336) 218-4242 - Archdale/Trinity: (336) 819-3262  
<http://www.co.randolph.nc.us>

CD - SEPTIC AUTHORIZATION FOR WASTEWATER SYSTEM CONSTRUCTION PER

Page 1 of 1



**COUNTY OF RANDOLPH**  
Health Department  
204 E Academy St - Asheboro NC 27204-0771

**IMPROVEMENTS PERMIT**

Improvements Permits are approvals for wastewater systems only, and are subject to revocation if the site or soil conditions are altered, the proposed facility, site plan or plat have changed, and the designed wastewater flow or wastewater characteristics have increased. **DO NOT GRADE OR DISTURB THE APPROVED SEPTIC SYSTEM AREA!** This is not a Construction Authorization Permit. A Construction Authorization Permit must be issued before any Building Permits can be obtained and before any construction begins on the property. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

Permit Type: SEPTIC NEW

Applicant: RANDOLPH COUNTY GOVERNMENT  
Address: 725 MCDOWELL RD  
City, St. Zip: ASHEBORO, NC 27203

Permit #: 2014-00000058  
Parcel #: 7625275672

  
Contact: WELLS, RICHARD  
Contact Phone: 336 318-6302

Owner: SHAW FARMS LLC  
Address: 6372 HIGH PINE CHURCH RD  
City, St. Zip: ASHEBORO, NC 27205

**LOCATION INFORMATION:**


Address: 6372 HIGH PINE CHURCH RD ASHEBORO, NC 27205  
Township: 20 - UNION Subdivision Name:  
Acreage: 87.45 Lot Number:

**FACILITY INFORMATION:**

Proposed Use:	SINGLE FAMILY RESIDENCE		
Wastewater Type:	DOMESTIC		
Design Flow:	240		
Number Of Bedrooms:	2	Basement:	NO
Number Of People/Employees:	4	Basement Fixtures:	
Number Of Shifts:			

Dispersal Type:	GRAVITY
Wastewater System Type:	GRAVEL TRENCH
Wastewater Sys Class:	TYPE II A CONV SYSTEM SFR <480 GPD

Issued By: WAYNE JONES  
Date Issued: 04/25/2014  
Expiration: 04/25/2019

  
Environmental Health Specialist:

- LOCAL TELEPHONE NUMBER -  
Asheboro: (336) 318-6262 - Greensboro/Liberty: (336) 218-4242 - Archdale/Trinity: (336) 819-3262  
<http://www.co.randolph.nc.us>

